



Part Number : [1301530048](#)

Product Description : Safeway In-Line Commercial GFCI, Permanent Mount, Single Phase, Manual Reset, NEMA 5-15, 15A, 120V, 15.24m (50.0') Cord Length

Series Number : 130153

Status : Active

Product Category : Power Distribution

Engineering Number : 15051-50



Documents & Resources

Drawings

[1301530048_sd.pdf](#)

Product Environment Compliance

Compliance

| | |
|--------------------|--------------|
| China RoHS | Not Reviewed |
| EU ELV | Not Reviewed |
| Low-Halogen Status | Not Reviewed |
| REACH SVHC | Not Reviewed |
| EU RoHS | Not Reviewed |

Multiple Part Product Compliance Statements

- Eu RoHS
- REACH SVHC
- Low-Halogen

Multiple Part Industry Compliance Documents

- IPC 1752A Class C
- IPC 1752A Class D
- Molex Product Compliance Declaration
- IEC-62474
- chemSHERPA (xml)

EU RoHS Certificate of Compliance

Part Details

General

| | |
|--------------------|--|
| Status | Active |
| Category | Power Distribution |
| Series | 130153 |
| Description | Safeway In-Line Commercial GFCI, Permanent Mount, Single Phase, Manual Reset, NEMA 5-15, 15A, 120V, 15.24m (50.0') Cord Length |
| Enclosure Rating | NEMA 4 |
| NEMA Configuration | NEMA 5-15 |
| Product Name | Safeway |
| Type | GFCI Commercial Duty, Single Phase |
| UPC | 78678833567 |

Agency

| | |
|-----|--------|
| CSA | LR6837 |
| UL | E66308 |

Electrical

| | |
|-------------------------------|-------------|
| Current - Maximum per Contact | 15.0A |
| GFCI | Yes-In-line |
| GFCI Reset | Manual |
| Ground Continuity Monitor | No |
| Open Neutral Relay | Yes |
| Voltage - Maximum | 125V |

Physical

| | |
|---------------------|-------------------------|
| Cord Diameter | 10.92mm (.430") |
| Cord Grip Body Size | Internal Double C-Clamp |
| Cord Length | 15.24m (50.0') |
| Cord Type | 14/3 SJTW |
| Feed-Thru | Yes |
| Flip Lid | No |
| Material - Housing | Nylon |

| | |
|-----------------------|----------|
| Mounting Style | Portable |
| Number of Receptacles | 1 |
| Packaging Type | Bag |
| Receptacle Type | N/A |

This document was generated on Mar 27, 2025